

1224

**UNDERGROUND STORAGE TANKS RELEASE  
REPORTS**

**06/21/90**

**DOE-1266-90  
DOE-FMPC/STATE FIRE MARSHAL  
2  
LETTER**



**Department of Energy**

1224

**FMPC Site Office**  
P.O. Box 398705  
Cincinnati, Ohio 45239-8705  
(513) 738-6319

June 21, 1990  
DOE-1266-90

Mr. Kelly Gill  
Division of State Fire Marshal  
Bureau of Underground Storage Tanks  
7510 East Main Street, P.O. Box 525  
Reynoldsburg, Ohio 430268-3395

**UNDERGROUND STORAGE TANKS RELEASE REPORTS**

Dear Mr. Gill:

On May 8, 1990, the U.S. Department of Energy reported to the State Fire Marshal that four of the FMPC's Underground Storage Tanks (USTs) contain water:

<u>Tank No.</u>	<u>Approximate Volume of Water</u>
UST #8	400 gallons
UST #9	1000 gallons
UST #10	240 gallons
UST #13	2000 gallons

In accordance with the UST regulations, the water in the tanks was reported to the Fire Marshal's Office as indicative of suspected releases. The four tanks listed above are not in service and are planned to be closed in accordance with the regulations.

The UST regulations also require that a site investigation report and an initial corrective actions report be provided to the Fire Marshal within 20 days of the release discovery. On May 24, 1990, Mr. Craig Smith of the Fire Marshal's staff advised the Feed Materials Production Center (FMPC) that the 20-day reports were not necessary because a thorough assessment of any releases will be done in conjunction with the removal of the tanks this summer. As instructed by Mr. Smith, DOE will not pursue the preparation of the reports for USTs #8, #9, #10, and #13 and will concentrate efforts on the closures of the tanks. DOE will continue to report any future releases or suspected releases.

1224

If your staff has any questions, or require additional information,  
please contact David Rast of my staff at (513) 738-6322.

Sincerely,

A large, stylized handwritten signature in black ink, appearing to read "G. Westerbeck". The signature is written over the typed name and title.

Gerald W. Westerbeck  
FMPC Site Manager

DP-84:Rast

cc:

E. D. Savage, WMCO