

3263

**FEMP WASTEWATER TREATMENT PLANT SELF-MONITORING REPORT VIOLATIONS FOR FEBRUARY, 1992
NPDES PERMIT NO. 1I000004*CD OH0009580
HAMILTON COUNTY**

**05/14/92
OEPA/DOE-FN
2
LETTER**



State of Ohio Environmental Protection Agency

Southwest District Office

40 South Main Street
Dayton, Ohio 45402-2086
(513) 285-6357
FAX (513) 285-6404

F-3146

FILE
LIBRARY ARJ

MAY 15 10 47 AM '92

3263
George V. Voinovich
Governor

May 14, 1992

Re: FEMP
WASTEWATER TREATMENT PLANT
SELF-MONITORING REPORT
VIOLATIONS FOR FEBRUARY, 1992
NPDES PERMIT NO. 1I000004*CD
OH0009580
HAMILTON COUNTY

Mr. Gerald W. Westerbeck
U.S. Department of Energy
FEMP
P.O. Box 398705
Fernald, Ohio 45239

Dear Mr. Westerbeck:

We have received your self-monitoring report covering the month of February, 1992, for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance was as follows:

EFFLUENT LIMIT VIOLATIONS

<u>Parameter</u>	<u>Code</u>	<u>Permit Limitation</u>	<u>Reported</u>
pH	00401	1.0 hrs. (duration)	4.5 hrs.

Please be advised that failure to comply with the effluent limitations of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reason for the above violation and the action being taken to prevent further occurrences. No additional information is requested at this time.

If you have any questions regarding the above, please contact me at this office.

Sincerely,


David M. Okerbloom
Division of Water Pollution Control
Compliance and Enforcement

DMO/acn

cc: DWPC, Enforcement and Compliance Section
Graham Mitchell, OEPA, SWDO