

3536

**U.S. DOE FEMP WASTEWATER TREATMENT
PLANT SELF-MONITORING REPORT
VIOLATIONS FOR APRIL, 1992 NPDES PERMIT
NO. 11000004*CD OH00095380 HAMILTON
COUNTY**

07/07/92

OEPA/DOE-FN

1

LETTER



State of Ohio Environmental Protection Agency

Southwest District Office

40 South Main Street
Dayton, Ohio 45402-2086
(513) 285-6357
FAX (513) 285-6404

3536

LIBRARY

JUL 10 11 44 AM '92

George V. Voinovich
Governor

July 7, 1992

Re: **U.S. DOE FEMP
WASTEWATER TREATMENT PLANT
SELF-MONITORING REPORT
VIOLATIONS FOR APRIL, 1992
NPDES PERMIT NO. 11000004*CD
OH0009580
HAMILTON COUNTY**

Mr. G.W. Westerbeck
U.S. DOE FEMP
P.O. Box 398705
Fernald, Ohio 45239

Dear Mr. Westerbeck:

We have received your self-monitoring report covering the month of April, 1992, for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance was as follows:

Effluent Limit Violations
Outfall 605

<u>Parameter</u>	<u>Code</u>	<u>Permit Limitation</u>	<u>Reported</u>
Nickel	01067	29 ug/l (mo. avg.)	30 ug/l

Please be advised that failure to comply with the effluent limitations of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reason for the above violation and the action being taken to prevent further occurrences. No additional information is requested at this time.

If you have any questions regarding the above, please contact me at this office.

Sincerely,


David M. Okerbloom

DMO/mlf

000 1

