

3984

WASTEWATER TREATMENT PLANT SELF-MONITORING REPORT VIOLATIONS FOR SEPT. 1992 NPDES PERMIT NO. 11O00004*CD APPLICATION NO. OH0009580 HAMILTON COUNTY

12/03/92

**OEPA/DOE-FN
1
LETTER**



State of Ohio Environmental Protection Agency

Southwest District Office

40 South Main Street
Dayton, Ohio 45402-2086
(513) 285-6357
FAX (513) 285-6404

LOG G-01084
FILE AR
LIBRARY

DEC 8 10 47 AM '92

3984

George V. Voinovich
Governor

December 3, 1992

Re: WASTEWATER TREATMENT PLANT
SELF-MONITORING REPORT
VIOLATIONS FOR SEPT., 1992
NPDES PERMIT NO. 1I000004*CD
APPLICATION NO. OH0009580
HAMILTON COUNTY

Mr. G. W. Westerbeck
FEMP
P.O. Box 398705
Fernald, Ohio 45239

[REDACTED]

Dear Mr. Westerbeck:

We have received your self-monitoring report covering the month of September, 1992, for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance was as follows:

EFFLUENT LIMIT VIOLATIONS

<u>Parameter</u>	<u>Code</u>	<u>Permit Limitation</u>	<u>Reported</u>
Fecal Coliforms	31616	2,000/100 ml (wk.avg.)	5,070/100 ml

(Station Numbers: 1I000004601-STP)

Please be advised that failure to comply with the effluent limitations of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reason for the above violation and the action being taken to prevent further occurrences. No additional information is requested at this time.

If you have any questions regarding the above, please contact me at this office.

Sincerely,

David M. Okerbloom
David M. Okerbloom
Division of Water Pollution Control
Compliance and Enforcement

DMO/acp

cc: DWPC, Enforcement and Compliance Section, CO