

5558

RI/FS WORKPLAN MODIFICATION FMPC OH6 890 008 976

09/19/89

USEPA
1
LETTER

DOE-FN

555 8



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 5
230 SOUTH DEARBORN ST.
CHICAGO, ILLINOIS 60604

SEP 19 1989

5HR-12

REPLY TO ATTENTION OF:

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. James Reafsnyder
United States Department of Energy
FMPC Site Office
P.O. Box 398705
Cincinnati, Ohio 45239-8705

Re: RI/FS Workplan Modification
Feed Materials Production
Center
OH6 890 008 976

Dear Mr. Reafsnyder:

This is in response to your letter dated September 18, 1989, requesting a modification to the Feed Materials Production Center RI/FS Workplan.

The United States Environmental Protection Agency hereby approves the installation of 2-inch diameter groundwater monitoring wells on the Albright and Wilson property. This is a modification of the RI/FS Workplan which required installation of 4-inch diameter wells at this location.

All other well installation and construction procedures and the well locations must conform to the RI/FS Workplan.

Please contact me at (312) 886-4448 if you have any questions regarding this matter.

Sincerely,

Kevin M. Pierard, Chief
Minnesota/Ohio Technical Enforcement Section

cc: G. Mitchell, OEPA

SEP 22 1989

Date Rec'd _____
C-2674
Library _____

1