

6607

G-000-104 .157

**FERNALD ENVIRONMENTAL MANAGEMENT PROJECT (FEMP) - OEPA
FACILITY NO. 143110128 NOTIFICATION OF INSTALLATION
CERTIFICATION, PTI 14-3348 - RESPIRATOR WASHING
FACILITY**

02/16/95

**C:EC:95-0032
FERMCO HAMILTON COUNTY
3
PTI**



Restoration Management Corporation

P.O. Box 398704 Cincinnati, Ohio 45239-8704 (513) 738-6200

February 16, 1995

Fernald Environmental Management Project
Letter No. C:EC:95-0032

Mr. Peter Sturdevant
Compliance Specialist
Air Quality Management
Hamilton County Department
of Environmental Services
1632 Central Parkway
Cincinnati, Ohio 45210

Dear Mr. Sturdevant:

**FERNALD ENVIRONMENTAL MANAGEMENT PROJECT (FEMP) - OEPA FACILITY NO. 143110128
NOTIFICATION OF INSTALLATION CERTIFICATION, PTI 14-3348 - RESPIRATOR WASHING
FACILITY**

Enclosed is the Installation Certification form for the Respirator Washing Facility (PTI 14-3348). The certification form has been signed with the understanding that the Respirator Washing Facility has been constructed in accordance with the Permit to Install application and the terms and conditions of the Permit to Install with two minor exceptions. These are:

- (1) Only one of the two combination washer/dryer units described in the PTI application was installed. If the additional washer/dryer unit is required to process respirators at the rates indicated in the PTI application, the second unit will be installed. We will notify you under separate cover should the second unit be installed.
- (2) The process flow diagram (PFD) indicates that the exhaust from the wet vacuum was to be routed directly to the HEPA filter system. The intent and the actual construction of the facility vents this exhaust directly into the Respirator Washing Facility room. Room air is drawn into HEPA system via HEPA system pickup points at the respirator unloading station and at the hood over the sink. The wet vacuum is used to remove excess moisture from cleaned respirators prior to placement into the dryers.



6607

Mr. Peter Sturdevant
Letter No. C:EC:95-0032
Page 2

Please contact Kip Klee of my staff at 738-8640 if you have any questions regarding this certification.

Sincerely,

A handwritten signature in black ink, appearing to read "Terence D. Hagen", with a long horizontal flourish extending to the right.

Terence D. Hagen, Director
Environmental Compliance

TDH:KOK:mhv
Enclosure

c: S. M. Beckman, FERMCO/MS65-2
J. R. Leist, FERMCO/MS64
B. D. Myers, FERMCO/MS44
L. E. Parsons, DOE Contract Specialist/MS45
W. J. Quaid, DOE-FN/MS45
P. B. Spotts, FERMCO/MS65-2
AR Coordinator/MS78
File Record Storage Copy 108.6
RTS Files (PTI File 14-3348)

INSTALLATION CERTIFICATION

TO BE FILED UPON COMPLETION OF CONSTRUCTION AND PRIOR TO STARTUP

FACILITY NAME: US DEPT OF ENERGY - FEMP

MAILING ADDRESS: STEPHEN BECKMAN
P O BOX 398704
CINCINNATI, OH 45239

PERMIT TO INSTALL NO: 14-3348

SOURCE NO: 1431110128P284


TO BE COMPLETED BY APPLICANT

DATE OF COMPLETION OF CONSTRUCTION: February 13, 1995

HAVE YOU FILED FOR A PERMIT TO OPERATE? _____ YES X NO

This signature shall constitute personal affirmation that the source has been constructed in accordance with the terms and conditions in the Permit to Install and Permit to Install Application and with all other applicable Ohio EPA requirements.

RETURN UPON COMPLETION OF CONSTRUCTION



Authorized Signature (for Facility)

2/16/95

Date

Terence D. Hagen

Name

Director, Environmental Compliance

Title

P. O. Box 538704 Cincinnati, OH 45253

Address

THIS CERTIFICATION SHOULD BE MAILED TO:

Cincinnati Air Pollution Control
1632 Central Parkway
Cincinnati, Ohio 45210