

286

~~5-402.13~~
600.7

**IMPLEMENTATION OF OPERABLE UNIT 5 RECORD OF DECISION -
TREATMENT OF DISCHARGES - FERNALD ENVIRONMENTAL MANAGEMENT
PROJECT**

05/21/96

DOE-0927-96
DOE-FN EPAS
2
OU5



Department of Energy

Ohio Field Office
Fernald Area Office

P. O. Box 538705
Cincinnati, Ohio 45253-8705
(513) 648-3155



286

MAY 21 1996
DOE-0927-96

Mr. James A. Saric, Remedial Project Director
U.S. Environmental Protection Agency
Region V - SRF-5J
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

Mr. Tom Schneider, Project Manager
Ohio Environmental Protection Agency
401 East 5th Street
Dayton, Ohio 45402-2911

Dear Mr. Saric and Mr. Schneider:

IMPLEMENTATION OF OPERABLE UNIT 5 RECORD OF DECISION - TREATMENT OF DISCHARGES - FERNALD ENVIRONMENTAL MANAGEMENT PROJECT

Reference: Letter DOE-0529-96, Johnny Reising to James A. Saric and Tom Schneider, "Implementation of Operable Unit 5 (OU5) Record of Decision - Treatment of Discharges at the Fernald Environmental Management Project," dated February 16, 1996.

Pursuant to Section 9.1.5 of the Operable Unit 5 (OU5) Record of Decision (ROD) the Fernald Environmental Management Project (FEMP) is required to provide written notification to the Ohio Environmental Protection Agency (OEPA) and the U.S. Environmental Protection Agency (U.S. EPA) within seven days of initiating a bypass of stormwater directly to the Great Miami River. Information requirements for this notification were defined in the reference.

The FEMP initiated a stormwater bypass at 12:15 pm, local time, on May 15, 1996, and lasted until 11:30 pm, local time, on May 19, 1996. A total of 4,654,000 gallons of stormwater were bypassed during this period. This bypass was necessary in an attempt to prevent an overflow of the stormwater retention basins. However, due to the intensity of the rainfall, the stormwater retention basins did overflow to Paddys Run. The overflow commenced at 2:30 pm, local time, on May 15, 1996, and lasted through 5:00 am, local time, on May 16, 1996. The stormwater bypass helped minimize the duration of the overflow event.

If you have any questions regarding our implementation of these requirements, please contact John Kappa at (513) 648-3149, or Robert Janke at (513) 648-3124.

Sincerely,



Johnny W. Reising
Fernald Remedial Action
Project Manager

FN:Kappa

cc:

L. Griffin, EM-423/GTN
R. L. Nace, EM-423/GTN
G. Jablonowski, USEPA-V, 5HRE-8J
Manager, TPSS/DERR, OEPA-Columbus
F. Bell, ATSDR
D. S. Ward, GeoTrans
R. Vandegrift, ODOH
S. McLellan, PRC
D. Carr, FERMCO/52-2
T. Hagen, FERMCO/65-2
J. Harmon, FERMCO/90
C. Little, FERMCO/2
M. Yates, FERMCO/9
AR Coordinator/78