



Department of Energy
Ohio Field Office
Fernald Environmental Management Project
P. O. Box 538705
Cincinnati, Ohio 45253-8705
(513) 648-3155



49 19

JUN 20 2003

Mr. James A. Saric, Remedial Project Manager
United States Environmental Protection Agency
Region V, SR-6J
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

DOE-0418-03

Mr. Tom Schneider, Project Manager
Ohio Environmental Protection Agency
401 East 5th Street
Dayton, Ohio 45402-2911

Dear Mr. Saric and Mr. Schneider:

NOTIFICATION OF STORM WATER BYPASS

In accordance with Section 9.1.5 of the Operable Unit 5 Record of Decision, the purpose of this letter is to inform you of a storm water bypass event. On June 14, 2003, at 2115 local time, a storm water bypass from the Storm Water Retention Basin (SWRB) to the Great Miami River was initiated. Bypassing continued until 2400 on June 18, 2003. The duration of the bypass event was 98.75 hours. A total of 4,356,000 gallons were bypassed during this event.

The bypass was initiated in an attempt to prevent an overflow of the SWRB to Paddys Run via the Storm Sewer Outfall Ditch. However, due to the intensity of the rainfall, an overflow did occur beginning on June 15, 2003 at 1500 and lasting until 2130 the same day. The duration of the overflow was 6.5 hours. Approximately 834,780 gallons overflowed the SWRB during this event.

If you have any question, please contact Robert Janke at (513) 648-3124.

Sincerely,

FCP:R.L.Janke

Glenn Griffiths
Acting Director

Mr. James A. Saric
Mr. Tom Schneider

-2-

DOE-0418-03

4919

cc:

R. Greenberg, EM-31/CLOV
N. Hallein, EM-31/CLOV
R. J. Janke, OH/FCP
K. Nickel, OH/FCP
E. Skintik, OH/FCP
J. Bartoszek, OEPA-Dayton
G. Jablonowski, USEPA-V, SR-6J
F. Bell, ATSDR
M. Cullerton, Tetra Tech
M. Shupe, HSI GeoTrans
R. Vandegrift, ODH
D. Brettschneider, Fluor Fernald, Inc./MS52-5
D. Carr, Fluor Fernald, Inc./MS1
M. Frank, Fluor Fernald, Inc./MS90
T. Hagen, Fluor Fernald, Inc./MS1
E. Henry, Fluor Fernald, Inc./MS52-5
W. Hertel, Fluor Fernald, Inc./MS52-5
M. Jewett, Fluor Fernald, Inc./MS52-5
F. Johnston, Fluor Fernald, Inc./MS52-5
M. Kopp, Fluor Fernald, Inc./MS52-5
T. Poff, Fluor Fernald, Inc./MS65-2
D. Powell, Fluor Fernald, Inc./MS64
AR Coordinator, Fluor Fernald, Inc./MS78
ECDC, Fluor Fernald, Inc./MS52-7