

B371/374 CLOSURE PROJECT

WEEKLY STATUS MEETING

9:30 am T371Z

AGENDA

February 23, 2005


D&D – Jim Floerke

WASHINGTON GROUP – Dan Coyne

FINAL SURVEY – Jay Britten

ACTION ITEMS

- Comment Resolution (Set 8 Final Survey Report)



ADMIN RECORD

B371 Project
Weekly Meeting 2/23/2005

Set/Area	D&D Status Jim Floerke			
Area AA	<ul style="list-style-type: none"> Zone 1 duct removed; miscellaneous piping in Rooms 1117/2327 removed; completing final survey/painting; completed in 1115, 1105, 1103, and 1003. 			
Area AC	<ul style="list-style-type: none"> Shaving/painting/final survey CSV. 			
Area AD	<ul style="list-style-type: none"> Zone 1 duct removed. Removing contaminated Zone II ducting. Removing contaminated Zone II filter plenums. Removing contaminated pass-throughs. 			
Area AE	<ul style="list-style-type: none"> Zone 1 duct removed. Removing contaminated Zone II ducting. Removing contaminated Zone II filter plenums. Removing contaminated pass-throughs. 			
Area AH	<ul style="list-style-type: none"> Decon/shaving canyon areas. Removing exhaust funnels/pass-throughs.. 			
Duct Removal Summary	<ul style="list-style-type: none"> Main floor – 100% complete Basement - 100% complete (9,689 of 9,689 linear feet removed) Sub-basement - 100% complete (942 of 942 linear feet removed) 			
Washington Group Activities Dan Coyne				
<table border="0" style="width: 100%;"> <tr> <td style="vertical-align: top; width: 50%;"> <ul style="list-style-type: none"> Sets 1 and 2: Mechanical punchlist (piping/duct) removal. Set 3/4/5: Punchlist item removal (core drilling). Set 6: Continued dry decon (rooms 3561A/3549/3547). Set 7: All activity complete. Set 8: All activity complete. Set 9: Mechanical removal (duct/piping in room 1214). Set 10: Mechanical removal (hose reel piping). Set 12: Mechanical removal (duct/piping/supports). Set 13: Dry shaving decon in room 2327 (corners). Set 14: No activity. Set 16/17: Continued wall demo. </td> <td style="vertical-align: top; width: 50%;"> <ul style="list-style-type: none"> Set 23: Completed dry decon punchlist items. Set 24/25: All activity complete. Set 29/30: Continued punchlist final clean up. Set 38: Electrical removal (air gapping/RCRA items). Completed piping draining/removal for duct interference. Prepare for draining of chilled water piping. Set 39: Final survey in Phase II. Continued duct removal in Phase IV. Set 40: Continued FP-125A plenum removal. Set 41/46: No activity. Set 50: Continued FP-243 plenum removal. Area AP: Performing final survey. Completed asbestos abatement of floor tile in room 2107. Temporary electrical power maintenance. Continued bldg. 374 demo. backfill. Continued preparing T-Gen for removal. Office trailer relocation. </td> </tr> </table>			<ul style="list-style-type: none"> Sets 1 and 2: Mechanical punchlist (piping/duct) removal. Set 3/4/5: Punchlist item removal (core drilling). Set 6: Continued dry decon (rooms 3561A/3549/3547). Set 7: All activity complete. Set 8: All activity complete. Set 9: Mechanical removal (duct/piping in room 1214). Set 10: Mechanical removal (hose reel piping). Set 12: Mechanical removal (duct/piping/supports). Set 13: Dry shaving decon in room 2327 (corners). Set 14: No activity. Set 16/17: Continued wall demo. 	<ul style="list-style-type: none"> Set 23: Completed dry decon punchlist items. Set 24/25: All activity complete. Set 29/30: Continued punchlist final clean up. Set 38: Electrical removal (air gapping/RCRA items). Completed piping draining/removal for duct interference. Prepare for draining of chilled water piping. Set 39: Final survey in Phase II. Continued duct removal in Phase IV. Set 40: Continued FP-125A plenum removal. Set 41/46: No activity. Set 50: Continued FP-243 plenum removal. Area AP: Performing final survey. Completed asbestos abatement of floor tile in room 2107. Temporary electrical power maintenance. Continued bldg. 374 demo. backfill. Continued preparing T-Gen for removal. Office trailer relocation.
<ul style="list-style-type: none"> Sets 1 and 2: Mechanical punchlist (piping/duct) removal. Set 3/4/5: Punchlist item removal (core drilling). Set 6: Continued dry decon (rooms 3561A/3549/3547). Set 7: All activity complete. Set 8: All activity complete. Set 9: Mechanical removal (duct/piping in room 1214). Set 10: Mechanical removal (hose reel piping). Set 12: Mechanical removal (duct/piping/supports). Set 13: Dry shaving decon in room 2327 (corners). Set 14: No activity. Set 16/17: Continued wall demo. 	<ul style="list-style-type: none"> Set 23: Completed dry decon punchlist items. Set 24/25: All activity complete. Set 29/30: Continued punchlist final clean up. Set 38: Electrical removal (air gapping/RCRA items). Completed piping draining/removal for duct interference. Prepare for draining of chilled water piping. Set 39: Final survey in Phase II. Continued duct removal in Phase IV. Set 40: Continued FP-125A plenum removal. Set 41/46: No activity. Set 50: Continued FP-243 plenum removal. Area AP: Performing final survey. Completed asbestos abatement of floor tile in room 2107. Temporary electrical power maintenance. Continued bldg. 374 demo. backfill. Continued preparing T-Gen for removal. Office trailer relocation. 			

B371 Project
Weekly Meeting 2/23/2005

Final Survey – Jay Britten

Phase II			Phase III		
B374	Total Scan m² Required	Scan m² Completed	B371	Total Scan m² Required	Scan m² Completed
Class I	142	142	Class I	TBD	TBD
Class II	1,519	1,519	Class II	TBD	TBD
Class III	<u>1,166</u>	<u>1,166</u>	Class III	TBD	TBD
	2,827	2,827			
		% Complete: 100%		Total m² Complete:	TBD
				% Complete:	0%
Phase IV					
B371	Total Scan m² Required	Scan m² Completed			
Class I	TBD	0			
Class II	TBD	0			
Class III	TBD	0			
		Total m² Complete: 0			
		% Complete: 0%			