

**ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE
REGULATORY CONTACT RECORD**

Date: November 29, 2001

Site Contact(s): Rob Garren (URS Group, Inc.)

Extension: X2609

Regulatory Contact: Arch Crouse

Extension: X2793 or (303) 692-3156

Agency: Colorado Department of Public Health and Environment, Air Pollution Control Division
(CDPHE, APCD)

Purpose of Contact (include topics discussed and documentation supplied):

CDPHE, APCD representative Arch Crouse was notified by K-H ESS representative Rob Garren on November 29, 2001 that Building 886 Demolition Project representatives are planning to lease a diesel fuel-fired generator to provide temporary power to support Building 886 pre-demolition activities.

Based on discussions with Mr. Crouse, the fuel-fired generator is exempt from air quality regulatory reporting and permitting requirements at this time. The generator meets the non-road engine exemption as outlined in Colorado Air Quality Control Commission Regulation No. 3.A.II.D.1.sss.1.iii and vi.

Follow-up required (list any documents requested): Project personnel will be required to provide the hour meter reading for the generator to Air Quality Management personnel at the beginning of each month while the unit is on Site.

Contact Record Prepared by: Rob Garren

Distribution:

P. Arnold, K-H 371
J. Berardini, K-H MS
A. Crouse, CDPHE
C. Deck, K-H Legal
J. Dion, DOE, RFFO
R. Garren, ESS
C. Gilbreath, K-H 771
T. Hopkins, K-H 707/776
S. Nesta, K-H RISS
R. Nininger, K-H ESS
K. North, K-H ESS
M. Putney, ESS
A. Rosenman, K-H ESS

