

Instructions for Completion of Type 1 Facility Closeout Report

Section A. Facility Data	
Facility No.	280, 282, and 284
Facility Descriptor:	Landfill Support Facility, 8,515 square feet
Project:	RISS – Area 3 D&D
Date of Demolition:	September 9, 2002
Additional Information:	Single story metal-frame buildings on concrete foundation and floor, demolished and disposed of as sanitary waste. Utilities were removed to three feet below grade in accordance with site configuration control procedures. A map of utility disconnect locations will be maintained and submitted to the AR on project completion. Site restoration will be performed during the final land configuration for Rocky Flats. A letter from CDPHE dated 10/15/02, approves the Final Closure Plan for the New Sanitary Landfill at RFETS, which will be completed at a point in time in the future.
<i>(Must include information on environmental releases and conditions of site at turnover to Environmental Restoration)</i>	

Section B. Final Characterization Data	
Reconnaissance Level Characterization Report <i>(concurrence received)</i>	Reconnaissance Level Characterization Report for Group D Buildings – Concurrence, Steven H. Gunderson to Joseph A. Legare, dated August 21, 2002, attached.
In-process Characterization	N/A
Pre-Demolition Survey Report <i>(approval received)</i>	N/A
Post-Demolition Survey Report <i>(as necessary)</i>	N/A

Section C. Waste Data <i>(complete categories as appropriate)</i>	
Sanitary Disposal	
Disposal Site:	Front Range Landfill, Erie, Colorado
Waste Volume (m ³):	505 Cubic yards
Waste Weight (tons):	178 tons
Additional Information:	Above grade building debris
Hazardous Disposal	
Disposal Site:	Kettleman Hills Facility, Kettleman City, CA or Bethlehem Apparatus Co, Hellertown, PA
Waste Volume (m ³):	Minor amounts
Additional Information:	Electronic circuit boards, thermostats, exit signs, batteries, fluorescent light bulbs and any other RCRA hazardous components were removed and taken to the RFCA temporary unit for combination with like waste streams for disposal.
TSCA Waste Disposal	
Disposal Site:	Salesco, Phoenix, AZ; Clean Harbors Deer Park, Deer Park, TX; or BFI Tower Rd. Landfill, Commerce City, CO
Waste Volume (m ³):	Minor amounts
Additional Information:	PCB ballasts were removed and taken to the RFCA temporary unit for combination with like waste streams for disposal.
Asbestos Waste Disposal	
Disposal Site:	
Waste Volume (m ³):	N/A
Additional Information:	
Low-Level Waste Disposal	
Disposal Site:	
Waste Volume (m ³):	N/A
Additional Information:	
Low-Level Mixed Waste Disposal	
Disposal Site:	
Waste Volume (m ³):	N/A

NOV 2002
RECEIVED
RECORDS CENTER

25678

BZ-A-000582

ADMIN RECORD

IA-A-001141

1/4

Instructions for Completion of Type 1 Facility Closeout Report

Additional Information:	
Recycled Material	
Recycle Facility:	PU&D
Waste Volume (m³):	76 m ³
Additional Information:	Metal for recycling
Recycled Material	
Recycle Facility:	RFETS Concrete Staging Pile - 850
Waste Volume (m³):	1058 tons
Additional Information:	Concrete for on-site backfill
Property Disposition	
Receiver Locations (major items only):	N/A
Volume (m³):	
Weight (tons):	
Additional Information:	

Section D. Approvals	
Kaiser-Hill Project Manager	10/31/02
Name/Signature	Date

File R.F.I. 4.1.2
Group D Facilitator
DOE/KM

STATE OF COLORADO

Bill Owens, Governor
Jane E. Norton, Executive Director

Dedicated to protecting and improving the health and environment of the people of Colorado

4300 Cherry Creek Dr. S.
Denver, Colorado 80246-1530
Phone (303) 692-2000
TDD Line (303) 691-7700
Located in Glendale, Colorado

Laboratory and Radiation Services Division
8100 Lowry Blvd.
Denver, Colorado 80230-6928
(303) 692-3090

<http://www.cdphe.state.co.us>



Colorado Department
of Public Health
and Environment

August 21, 2001

Mr. Joseph A Legare
Assistant Manager for Environment and Infrastructure
U.S. Department of Energy, Rocky Flats Field Office
10808 Highway 93, Unit A
Golden, CO 80403-8200

RE: Reconnaissance Level Characterization Report (RLCR) for Group D Buildings -
Concurrence

Dear Mr. Legare:

The Colorado Department of Public Health and Environment, Hazardous Materials and Waste Management Division has reviewed the RLCR for Group D Buildings, Revision 0 dated July 16, 2001, which was received on August 16, 2001. Based on the information contained in this RLCR, we are hereby concurring with the Type 1 designation for the Group D Buildings. The Group D Buildings are identified as Buildings 280, 281, S281, 282, 284, 442W, T551A, T900D, T886B, and T886C.


Although these buildings are currently identified as Type 1 Facilities, some of these facilities are still being utilized, such as T886B and T886C. As such, even with "Administrative Controls" (signs) contamination may inadvertently be carried or brought into these facilities. Therefore, additional assessments including investigations should be performed upon termination of active utilization. The consultative process should be utilized to acquire and provide this information prior to final disposition of these facilities.

It is indicated in this report that Beryllium samples may have been collected on ceilings, rather than on horizontal surfaces. In Table H-3, it is stated, "future random samples should be limited to horizontal surfaces facing upward." We agree with this concern for random samples. However, we also believe that collecting samples on the ceiling may be appropriate if these samples are collected from dusty areas such as next to ventilation ducts. Therefore, as stated in the RLCR and PDS Plans, samples should be collected in areas with the highest potential for finding possible contamination, where dust may have

collected. As such, biased samples are to be collected for beryllium rather than random samples.

If you have any questions regarding this correspondence please contact me at (303) 692-3367 or David Kruchek at (303) 692-3328.

Sincerely,



Steven H. Gunderson
RFCA Project Coordinator

cc: Steve Tower, FC, RFFO
Tim Rehder, EPA
Tom Scott, KH
Dave Shelton, KH
Frank Gibbs, KH
Administrative Records Building 850

Post-It® Fax Note	7671	Date	9/21	Pages	2
To	Steve Tower	From	D Kruchek		
Co./Dept.	DOE	Co.	CDPHE		
Phone #	966 2133	Phone #	692 3328		
Fax #		Fax #			

4/4