

Type 1 Facility Closeout Report

| | |
|---|---|
| Section A. Facility Data | |
| Facility No. | 827 |
| Facility Descriptor: | Emergency Generator Building – 800 ft |
| Project: | RISS – D&D Area 1 |
| Date of Demolition: | March 27, 2003 |
| Additional Information: | The building had metal siding and a concrete slab. The structure was demolished including the slab and disposed of as sanitary waste. Electric and fuel utilities were all disconnected to more than three feet below grade prior to structure demolition in accordance with site configuration control procedures. There was no sanitary sewer, water or fire utilities associated with this facility. In addition, fuel oil tank #25 (UST), which was closed under RFCA Attachment 13, was removed and disposed of as sanitary waste. A map of all underground utility disconnect locations will be maintained and submitted to the AR on project completion. Site restoration will be performed during the final land configuration for Rocky Flats. |
| <i>(Must include information on environmental releases and conditions of site at turnover to Environmental Restoration)</i> | |

| | |
|--|---|
| Section B. Final Characterization Data | |
| Reconnaissance Level Characterization Report <i>(concurrence received)</i> | Approval letter from CDPHE dated May 22, 2002 |
| In-process Characterization | N/A |
| Pre-Demolition Survey Report <i>(approval received)</i> | N/A |
| Post-Demolition Survey Report <i>(as necessary)</i> | N/A |

| | |
|--|--|
| Section C. Waste Data <i>(complete categories as appropriate)</i> | |
| Sanitary Disposal | |
| Disposal Site: | BFI Tower Road Landfill, Denver, Colorado |
| Waste Volume (m³): | 46 m ³ |
| Waste Weight (tons): | 9.8 tons |
| Additional Information: | Above ground building debris |
| Disposal Site: | Front Range Landfill, Erie, Colorado |
| Waste Volume (m³): | 191 m ³ |
| Waste Weight (tons): | 118.25 tons |
| Additional Information: | Concrete from slab, UST vault and UST #25 which was closed under RFCA Attachment 13. |
| Hazardous Disposal | |
| Disposal Site: | Kettleman Hills Facility, Kettleman City, CA or Bethlehem Apparatus Co, Hellertown, PA |
| Waste Volume (m³): | Minor Amounts |
| Additional Information: | Electronic equipment, thermostats, exit signs, batteries, fluorescent light bulbs and any other RCRA hazardous components were removed and taken to the RFCA temporary unit for combination with like waste streams for proper disposal. |
| TSCA Waste Disposal | |
| Disposal Site: | N/A |
| Waste Volume (m³): | |
| Additional Information: | |
| Asbestos Waste Disposal | |
| Disposal Site: | N/A |
| Waste Volume (m³): | |
| Additional Information: | |

1/2

Type 1 Facility Closeout Report

Section C. Waste Data (complete categories as appropriate)

Low-Level Waste Disposal

Disposal Site: N/A

Waste Volume (m³):

Additional Information:

Low-Level Mixed Waste Disposal

Disposal Site: N/A

Waste Volume (m³):

Additional Information:

Recycled Material

Recycle Facility: N/A

Waste Volume (m³):

Additional Information:

Property Disposition

Receiver Locations (major items only): N/A

Volume (m³):

Weight (tons):

Additional Information:

Section D. Approvals

Kaiser-Hill Project Manager

Karen A. Wenzel
Name/Signature

4/17/03
Date

2/2

