

ER REGULATORY CONTACT RECORD

Date/Time March 17, 2004/12 30

Site Contact(s) Annette Primrose , Karen Wiemelt, Cameron Freiboth, Steve Nesta
Phone 303 966-4385 303 966-9883 303 966-2823 303 966-6386

Regulatory Contact David Kruchek
Phone 303 692-3328

Agency CDPHE

Purpose of Contact Closure of Sanitary Sewer in the Contractor Yard area

Discussion

At the weekly RISS Integration Meeting, the approach for closing the sanitary sewer in the Contractor Yard was discussed. A map showing the sanitary sewer lines, 14 manholes and 2 lift stations in this area was provided along with a brief discussion on how each would be dispositioned.

The approach agreed upon for this area is, in summary

- Remove all pipelines and structures that are within 3 feet of current or proposed future ground surface, whichever is lower, along with other collocated infrastructure
- Perform radiological surveys of the inlets and outlets for manholes and lift stations. Additional actions may be required as a result of these surveys
- Plug and grout any open ends of the sanitary sewer lines, along with the inlets and outlets at manholes and lift stations
- Grout and backfill the manholes and lift stations to the current or proposed future ground surface, which ever is greater

Contact Record Prepared By Annette Primrose

Required Distribution

M Aguilar, USEPA
 S Bell, DOE-RFFO
 J Berardini, K-H
 B Birk, DOE-RFFO
 L Brooks, K-H ESS
 M Broussard, K-H RISS
 L Butler, K-H RISS
 G Carnival, K-H RISS
 N Castaneda, DOE-RFFO
 C Deck, K-H Legal
 S Gunderson, CDPHE
 M Keating, K-H RISS
 G Kleeman, USEPA
 D Kruchek, CDPHE
 D Mayo, K-H RISS

R McCallister, DOE-RFFO
 J Mead, K-H ESS
 S Nesta, K-H RISS
 L Norland, K-H RISS
 K North, K-H ESS
 E Pottorff, CDPHE
 A Primrose, K-H RISS
 R Schassburger, DOE-RFFO
 S Serreze, K-H RISS
 D Shelton, K-H ESS
 C Spreng, CDPHE
 S Surovchak, DOE-RFFO
 K Wiemelt, K-H RISS
 C Zahm, K-H Legal

Additional Distribution

John Stover, DOE
Joe Lucerna, K-H RISS
Robert Fiehweg, K-H RISS
Gary Morgan, DOE
Edgar Ethington, CDPHE

