

**ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE
REGULATORY CONTACT RECORD**

Date/Time: July 19, 2004 / 1500

Site Contact(s): Steve Nesta
Phone: 303-966-6386

Regulatory Contact: Harlen Ainscough
Phone: 303-692-3337

Agency: CDPHE

Purpose of Contact: CONCURRENCE FOR RCRA STABLE STATUS OF VALVE VAULTS 12 &13

Discussion

Site personnel are continuing to conduct RCRA closure of the NPWL and associated valve vaults. Crews recently conducted the initial blow down of the process waste lines from valve vault 12 &13 to Tank 231B. The area has been physically and electrically isolated. In order to take the next steps of disconnecting the electricity, and removing the alarms, Mr. Ainscough was contacted and agreed that the alarms can be disconnected, and Site personnel can declare this portion of the system as RCRA Stable. With the change in status to RCRA Stable, the inspection frequency can be relaxed from weekly to quarterly, but will require inspection of the valve vaults following significant precipitation events.

Contact Record Prepared By: Steve Nesta

Required Distribution:

M. Aguilar, USEPA
S. Bell, DOE-RFPO
B. Birk, DOE-RFPO
C. Deck, K-H Legal
D. Foss, K-H 707/776/777
S. Garcia, USEPA
C. Gilbreath, K-H 771/774
S. Gunderson, CDPHE
J. Legare, DOE-RFPO

R. Leitner, K-H 371/374
J. Mead, K-H ESS
G. Morgan, DOE-RFPO
S. Nesta, K-H RISS
K. North, K-H ESS/MS
R. Schassburger, DOE-RFPO
D. Shelton, K-H ESS
C. Zahm, K-H Legal

Additional Distribution:

Harlen Ainscough

