

United States Government

Department of Energy  
Rocky Flats Field Office**memorandum**

DATE:

DEC 21 1994

REPLY TO

ATTN OF:

ER:BIW:12646

SUBJECT:

Operable Unit No. 1 and Operable Unit No. 2 Treatment Plant Consolidation.

TO:

Marla Broussard  
Manager for Environmental Operations  
EG&G Rocky Flats, Inc.

In light of the Operable Unit (OU) No. 7 manager recently deciding to pursue other onsite treatment options or to solicit bids on the treatment needs for the water to be collected as a part of the OU 7 IM/IRA (ER:KM:12638, dated December 16, 1994), there appears to be no current need to consolidate the OU 1 and OU 2 treatment systems.


The following reports seem to outline EG&G's expectations on water treatment needs:

Preliminary Plan For Future Utilization of Existing  
Water Treatment Facilities at Rocky Flats Plant,  
Phase I & II, (Draft)

The Draft Site Treatment Plan

Resource Document For The Planning of Shared  
TSD Facilities

Nowhere in these reports is there any mention of a specific anticipated waste stream that is sufficiently characterized to show it would require the combined OU 1 and OU 2 treatment capabilities. It is for this reason that we ask for a specific source sufficiently identified (i.e. concentrations of specific constituents known) to be shown prior to this consolidation being approved by the Department of Energy (DOE). For any consolidation plan to be considered by DOE, a costing and schedule plan should also be included.



000063342

ADMIN RECORD

SW-A-004218

1/2

1/2

M. Broussard  
ER:BIW:12646

2

DEC 21 1994

Within two weeks of receipt of this letter, I will ask that a BCP be prepared to return the funding in Work Package 12949 to Management Reserve unless there is a demonstrated need in writing from EG&G. Please direct any questions you may have to Brandon Williamson at extension 5276.



Brandon L. Williamson  
Facilities Team Lead  
Environmental Restoration

cc:  
J. Roberson, AMER, RFFO  
F. Lockhart, ER, RFFO  
B. Williamson, ER, RFFO  
K. Muenchow, ER, RFFO  
S. Grace, ER, RFFO  
J. Rampe, ERPO, RFFO  
J. Stewart, SAIC  
B. McCarthy, SAIC  
S. Stiger, EG&G  
M. Burmeister, EG&G

2/2

2/2