

**ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE
REGULATORY CONTACT RECORD**

Date/Time: July 15, 2003/ 4:15 pm

Site Contact(s): David Ward
Phone: 303-966-5938

Regulatory Contact: James Hindman
Phone: 303-966-4482

Agency: Colorado Department of Public Health and Environment

Purpose of Contact: Obtain approval to install a door in the wall/berm of Room 2804

Discussion

As part of the decommission and demolition (D&D) of B374 liquid operations equipment and supplies need to be brought into, and waste crates full of sludge and disassemble equipment need to be removed from Room 2804. The most appropriate method to access Room 2804 for this activity is to create an opening with a door in the wall/berm between Rooms 2804 and 2801. Since there are tanks in Room 2804 being used to transfer liquid waste from B371 to T231, State approval is being requested to use a seal around the door to maintain the appropriate secondary containment capacity. There are two sump pumps located in Room 2804, which are operational and pump to tanks in the room. The seal, which may be absorbent pigs, will be installed at the end of the last D&D shift of the day and removed at the first D&D entry into Room 2804 of the day. The State approved this method of maintaining the secondary containment since this is not an on going operation, is part of the D&D activity, and a sump pump is operational to pump spills.

Contact Record Prepared By: David Ward


Required Distribution:

P. Arnold, K-H 371
C. Deck, K-H
R. DiSalvo
C. Gilbreath, K-H 771
S. Gunderson, CDPHE
T. Hopkins, K-H 776
L. Kilpatrick, RFFO

J. Legare, DOE
R. Leitner, K-H 371
J. Mead, K-H ESS
S. Nesta, K-H RISS
K. North, K-H ESS/MS
B. Prymak, DOE
T. Rehder, USEPA
D. Shelton, K-H

Additional Distribution:

 D. Onyskiw _____



1
1