

Whiting, John

From: Kray, Edd
Sent: Wednesday, December 29, 1999 11:31 AM
To: Whiting, John
Subject: 779 Main building surveys

I'll Try again with a better address

----- Forwarded by Edd Kray/SiteReps/rffo on 12/29/99 11:29 AM -----



Edd Kray 12/29/99 11:10 AM * * * * *

To: David Nickless/AMPA/DMTP/rffo@RFFO
cc: aguilar.mark@EPAMAIL.epa.gov, chris.gilbreath@state.co.us, Steve Gunderson@state.co.us, Dorothy Newell/AMMSD/DMTP/rffo@RFFO, sarah.roberts/RFFO1/USDOE@EXCHANGE, steve.tarlton@state.co.us, John.whiting?/RFFO1?/USDOE@EXCHANGE @ CCM, Sandra MacLeod/AMEC/DMTP/rffo@RFFO
Subject: 779 Main building surveys

The State has received and reviewed the "Closeout Radiological Survey Report for Building 779, Main Building" and the "Non-Radiological Closeout Report for the Main Building, Utility Area and B-Annex". Our evaluation of the reports concludes that the surveys were appropriately performed and the resultant data fully supports the categorization of the building segment as free-releasable per the criteria set-forth within the Decommissioning Operations Plan.

The report was also reviewed by staff from EPA and concurrence with this conclusion received from Mr. Mark Aguilar.

We have also received concurrence from Mr. Art Similjin of the DOE contracted Independent Verification Team from Mactek Inc. verifying their agreement with the report.

Additionally, on December, 28, 1999, State and EPA staff directed the conduct of a set of biased surface survey measurements within the area. The results were consistent with the data in the final reports and found no contamination above the agreed-upon limits.

Based on these intensive reviews, verification efforts and quality assurance data, the State has significant confidence that the Building 779, Main Building structure meets the free-release requirements of the DOP and notes that these standards are consistent with those used in the commercial sector, outside the RFETS fence line. We concur with the KH conclusion that the building segment is suitable for demolition as described within the approved demolition plan.

Feel free to call me at (303) 966-2115 should any clarification be needed.

ADMIN RECORD
B779-A-000163