

copy to
F. Gibbs
J. Stevens

STATE OF COLORADO

Bill Owens, Governor
Jane E. Norton, Executive Director

Dedicated to protecting and improving the health and environment of the people of Colorado

HAZARDOUS MATERIALS AND WASTE MANAGEMENT DIVISION
<http://www.cdphe.state.co.us/hm/>

4300 Cherry Creek Dr. S. 222 S. 6th Street, Room 232
Denver, Colorado 80246-1530 Grand Junction, Colorado 81501-2768
Phone (303) 692-3300 Phone (970) 248-7164
Fax (303) 759-5355 Fax (970) 248-7198



Colorado Department
of Public Health
and Environment

October 4, 2000

Mr. Joseph A Legare
Assistant Manager for Environment and Infrastructure
U.S. Department of Energy, Rocky Flats Field Office
10808 Highway 93, Unit A
Golden, CO 80403-8200

RE: Reconnaissance Level Characterization Report (RLCR) for Building 331A of the Group C Facilities

Dear Mr. Legare:

The Colorado Department of Public Health and Environment, Hazardous Materials and Waste Management Division (the Division) has received supplemental information on Oct 3rd regarding previous concerns with B331A of the RLCR for Group C Facilities. This supplemental information includes revised RLCR pages #11 (Section 2.1) and #35 (Section 5.0 & Table 5-1).

Information provided indicates that the roof of B331A is constructed of sheet metal rather than "Transite" as previously stated in the RLCR. As such, the Division accepts the rationale indicating the elevated radioactive material detected on the roof is polonium rather than DOE-added material.

In addition, the 4 cement footers associated with B331A are indicated as a part of the waste volume to be generated during demolition of B331A. As indicated in the revised material, these footers will be excavated and appropriately characterized for proper disposal.

The Division is hereby concurring with the Type 1 designation for B331A as identified in the Group C RLCR, and as revised on October 3, 2000.

If you have any questions regarding this correspondence please contact David Kruchek at (303) 692-3328.

Sincerely,

Steven H. Gunderson
RFCA Project Coordinator

cc: Steve Tower, FCG, RFFO
Tim Rehder, EPA
Tom Scott, KH
Dave Shelton, KH
Administrative Records Building 850



ADMIN RECORD

IA-A-000559

1/1