



COLORADO
Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

August 31, 2015

Scott Surovchak
LM Site Manager
U.S. Department of Energy
11025 Dover Street, Suite 1000
Westminster, CO 80021-5573

RE: Contact Record 2015-07 - Vinyl chloride in Present Landfill Seep

Dear Mr. Surovchak,

The Colorado Department of Public Health and Environment (CDPHE), in coordination with Region 8 of the Environmental Protection Agency, has reviewed draft Contact Record 2015-07. This contact record describes the US Department of Energy's response to an exceedance of the surface water standard (i.e., practical quantitation limit or PQL) for vinyl chloride in the Present Landfill Treatment System effluent. The response included three subsequent monthly sampling events, which led to sampling at the NNG01 location. Because the results from the sampling at NNG01 were below the method detection limit, no further sampling was required.

The responses to the sampling results agree with protocols in Attachment 2 of the Rocky Flats Legacy Management Agreement. No additional actions are required and the normal quarterly sampling routine can be resumed.

Please let me know if you have any questions regarding this approval.

Sincerely,

Carl Spreng
RFLMA Project Coordinator

ec: Linda Kaiser, Stoller Newport News Nuclear (SN3)
David Ward, Stoller Newport News Nuclear (SN3)
Vera Moritz, EPA
Dan Miller, AGO
Walter Avramenko, CDPHE

